



**NOTES:**

- 1.) THE OWNER SHALL PROVIDE ALL PLUMBING SHOWN EXCEPT FOR THAT NOTED AS INSTALLED BY THE DISTRICT. THE PIPE SHALL BE SIZED TO MATCH THE SIZE OF THE SERVICE LINE ENTERING THE BUILDING OR THE SIZE THE SERVICE LINE HAS BEEN REDUCED TO.
- 2.) THE METER SHALL BE LOCATED IN A CLEAN, DRY AND ACCESSIBLE LOCATION MAINTAINED AT A TEMPERATURE CONTINUALLY ABOVE 45 DEGREES F. ALL METER LOCATIONS SHALL BE APPROVED BY THE DISTRICT.
- 3.) THE DISTRICT MAY RUN A WIRE TO THE EXTERIOR OF THE BUILDING FROM THE LOCATION OF THE METER TO A REMOTE READER OR RADIO. THIS SHOULD BE ACCOMPLISHED PRIOR TO INSTALLATION OF INSULATION OR FINISHED WALL SURFACES.

**TYPICAL METER INSTALLATION**  
**(1" OR SMALLER METER)**